General:

- 1. The Notes in this drawing shall be all relevant drawings. read in conjunction with
- 2. The Contractor shall verify all Chainages, Reduced Levels, Co-ordinates and Dimensions before work starts. In case of any discrepancy, the matter shall be brought to the notice of the Engineer-in-Charge.
- All the bridges are designed to carry worst effects of the following Road Live Loads as per IRC 6:2000
- foundations for pier/abutments resting on rock/soil is to be verified at site by the Contractor before execution in consultation with the Engineer—in—Charge. Safe bearing capacity considered in designing
- . U In case any localised soft soil deposit is noted at the founding level for foundations resting on rock, the same shall be excavated and replaced by M15 grade concrete.
- <u></u>ნ In case of foundations resting on rock, the annular space around the footing shall be filled back with concrete of M15 Grade mix upto the top of rock.
- œ Moderate conditions of exposure have been considered in the design of these bridges/flyovers. Wearing coat shall comprise of 50mm BC & 12mm Mastic with water proofing membrane (chemical compound)

7.

All dimensions are in millimetres and levels are in metres unless otherwise specified. Only written dimensions shall be followed . No drawing shall be scaled.

Concrete

- Minimum grand shall and shall have minimum 150mm cubes as follows: grade of Concrete for varies elements shall be des Il have minimum 28 days characteristics strength on design mix
- <u>a</u> PSC box type super structure Precast/Cast—in—situ PSC Precast Pretensioned | girders M45
- (e) (d)(c)(b) Sub structure main flyover Precast parapet/edge/kerb Pedestal of bearings PSC voided slab M45 M30 M45 M30
- Foundation main flyover pier/pier cap
- (f)(g)Foundation ramp portion Pile/pile cap M35 M35
- (H)Abutments and substrucutre Pile/pile cap M30
- \bigcirc $\widehat{=}$ Median Sub structure ROB portion ramp portion pier/pier cap M35 M30
- 2 High Strength Ordinary Portland Cement conforming to IS: 12269 and IS: 8112 or Ordinary Portland Cement conforming to IS:269 capable of achieving the required design concrete strength shall only be used. $\widehat{\Sigma}$ Open Foundation M30
- 3. To improve workability of concrete, admixtures conforming to IS:6925 and IS:9103 may be permitted subject to satisfactory proven use. Admixtures generating hydrogen, nitrogen should not be used.
- 4. Minimum cement content & maximum water cement ratio in concrete shall be as per Table 4 of IRC:21—2000 (Latest edition) for "Moderate Conditions of Exposure".
- $\dot{\Omega}$ Nominal maximum size of coarse aggregates to for all RCC works shall be 20mm. be used

R-0 REV

16.08.10

FOR TENDER PURPOSE DESCRIPTION OF REVISIONS

INTIALS

C.V.KAND CONSULTANTS PRIVATE LIMITED

C.V.KAND

CONSULTANTS PRIVATE LIMITED

201, 202 SAI EMPIRE BANER, PUNE-411045,
PHONE 020 66294444

PROJECT MANAGEMENT CONSULTANT:

Reinforcement:

- 1. All reinforcing steel shall be Part 1 Mild Steel). Grade Designation Fe 500 CRS conforming to IS:1786 (except for mesh reinforcement which MS Bars Grade Designation S 240 conforming :0 IS:432 shall be
- Bending of reinforcement bars shall be as per IS:2502.
- in such cases: possible. reinforcement bars Laps may be provided, if unavoidable. shall be avoided as However, far as
- (a) minimum lap length of clause 304.6.6 of IRC: 21 - 2000.reinforcement shall be as per
- not more than 50% of reinforcement bars shall be
- \bigcirc for closely spaced bars lapping may be avoided by laped at any one section.
- providing suitable type of mechanical splicing. shall
- 4. Minimum bond length for reinforced bars clause 304.6.2 of IRC 21-2000. be as per
- 5 Clear cover to any reinforcing steel closest to concrete facts shall be 40mm in case of superstructures and 50mm in case of substructures. Clear cover shall be 75mm in case of foundations. concrete face
- Welding of reinforcement bars shall not be permitted.
- Supporting chairs of 12mm diameter shall be provided at suitable intervals as per IS:2502.
- $\overset{\cdot}{\infty}$ Full cover shall be Full cover shall be maintained at grooves and architectural finishes to the concrete surface. and otherwise
- 9 Type of reinforcement is denoted by the following symbols the drawings :
- Mild Steel Bars Fe 500 CRS
- Spacing given for all reinforcement is unless otherwise shown on drawings. perpendicular to bars

<u>1</u>0.

Water

Water to be used in concreting and curing shall to clause 302.4 of IRC:21—2000 conform

Material Specifications :

Material specifications and workmanship shall be accordance with MORTH Specifications for Road Works -2001 and Technical Specifications as spelt out in the Tender Documents. & Bridge Ξ.

Workmanship Detailing

- All sharp edges of concrete shall be chamfered (10mmx10mm)
- Form work details shall be submitted by the Contractor for the approval and shall be tested in accordance with the specifications.

3. Construction joint

- (i) The locations and provision of construction joints shall be approved by the Engineer—in—Charge. The concreting operation shall be carried out continuously up to the construction joint.
- \equiv The preparation of construction joint shall conform to Appendix 1700/l of MOST's specifications for Road &Bridge Works Fourth Revision—2001, (Rerint: September2002).

4. Expansion joints

- (i) The strip seal type expansions joints shall be procured only from approved manufacturers as per the stipulations of the tender document.
- The working drawings for expansions joints shall be submitted by the Contractor / Manufacturer for approval prior to procurement.
- Manufacturer's representatives shall be available at at the time of, positioning of the embedded parts constallation of expansion joints. Abbreviations:

HFL	\dashv	ВP	SE	유	RC	R
			1	1	1	1
High Flood Level	Тор	Bearing Pad	Super Elevation	Chainage	Reinforced Concrete	Reduced Level
₩	\leq	FRL	EGL	Z _F	籽	Ħ
-	-		-			
Bottom	Length Varies	Finished Road Level	Existing Ground Level	Near Face	Both Faces	Earth Face

Lowest Bed Level

Low Water Level



CLIENT:

PIMPI RI CHINCHWAD MUNICIPAL CORPORATION

TITLE:

Design and Construction of Bridge on Pawana River, Flyover/Viaduct and ROB with Approaches & Ramps on Kalewadi Phata to Dehu Alandi Road PROJECT: GENERAL NOTES REVISION NO: RO DRG.NO. PCMC/KALEWADI/GN/01 DRAWN BY(A) DESIGN(B) CHECKED (C) APPROVED (D) DATE:01-10-2010